

**ATTAR TEST REPORT NUMBER: 11/5437.3**  
Replacement of ATTAR Test Report Number: 11/5391.3

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards. Accredited for compliance with ISO/IEC 17025. Accreditation Number: 2735

7 November 2011

**Total Pages: 1****OIL-WET RAMP SLIP RESISTANCE**

Job No: M11/5437

<b>Prepared for:</b>	FLOORChef Pty Ltd PO Box 6364 YATALA QLD 4207	
<b>Attention:</b>	Mr Jack Josephsen	
<b>Test Site:</b>	ATTAR, Unit 1, 64 Bridge Road, Keysborough.	
<b>Test Date:</b>	19 October 2011	
<b>Manufacturer:</b>	FLOORChef Pty Ltd	
<b>Test Specimen, Size &amp; Quantity:</b>	Grey FLOORChef Peppersteak Min, 54x106 cm, 1 off supplied.	
<b>Sampling &amp; Direction of Testing:</b>	Sampling conducted by client. Test direction not applicable.	
<b>Test Personnel:</b>	Steven Potts & Daniel King	
<b>Preparation:</b>	As received.	
<b>Joint Width:</b>	Not applicable	
<b>Air Temperature:</b>	23°C	
<b>Test Standard:</b>	AS/NZS 4586 - 2004 Slip resistance classification of new pedestrian surface materials – Appendix D.	
<b>Surface Structure :</b>	Profiled.	
<b>Classification Criteria:</b> (TABLE D3 in AS/NZS 4586- 2004)	<b>Corrected Mean Overall Acceptance Angle</b>	<b>Slip Resistance Assessment Group</b>
	6° to 10°	R9
	Over 10° to 19°	R10
	Over 19° to 27°	R11
	Over 27° to 35°	R12
	Over 35°	R13
<b>Displacement Space:</b>	Not Measured	
<b>Displacement Space Assessment Group:</b>	N/A	
<b>Mean Overall Acceptance Angle:</b>	<b>11.1°</b>	
<b>Slip Resistance Assessment Group:</b>	<b>R10</b>	

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

**NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.**

**ATTAR**Daniel King BEng(mat) Hons.,  
Graduate Engineer  
Approved Signatory

This report may not be reproduced except in its entirety.

**Page 1 of 1**